

Interferometry in space: lead-in talk

Robert Spero
Jet Propulsion Laboratory / California Institute of Technology
26 June 2012

GRACE: the first interferometer in space






GRACE Measurement as Time-Delay Interferometry



$$\phi_r(t) = [D_{21}D_{12} - 1] p_{21}(t)$$

 $D_{ij}a(t) = a(t - L_{ij}/c)$

- Conventional mirror-based self-delay interferometer
- Measurement is (prompt)—(delayed)



$$\phi_{21}(t) = D_{21}p_{12} - p_{21}(t)$$

$$\phi_{12}(t) = D_{12}p_{21}(t) - p_{12}(t)$$

$$\phi_{r}(t) = \phi_{21}(t) + D_{21}\phi_{12}(t)$$

- Synthesized from symmetric one-way measurements
- Two lasers, two measurements
- Measurements combined using knowledge of delays






Michelson interferometry by TDI

Simplest TDI combination canceling frequency noise: Michelson interferometer

- Separate lasers and phasemeters at vertex
- Arms are unequal, optical subtraction would be sensitive to frequency noise
- Symmetrized path synthesized by delaying and adding separate arm measurements
- Rejection of frequency noise limited only by knowledge of delays
- Same sensitivity to differential strain as conventional Michelson



First-order Shaddock Diagram

Prime candidate for quantum techniques in space: DECIGO gravitational-wave detector

No options for squeezing on LISA -- Yanbei's talk yesterday -- but DECIGO (or BBO or Astrod,...) is another story






Figure 1. Pre-conceptual design of DECIGO.

2003 concept: Big gap to quantum limit



Current concept: Limited by radiation pressure below 0.15 Hz, shot noise above 0.15 Hz



Practical Limits

• Phase squeezing: Finesse = 10 implies large optical loss, limiting improvement at high frequency from squeezing. But, should be easy to increase finesse.

• Amplitude squeezing: 1000 times better acceleration noise

than LISA: very difficult!

